


1 ANNEX FIRST FLOOR POWER PLAN
SCALE: 1/4"=1'-0"

GENERAL NOTES:

1. PROCESS EQUIPMENT LOAD INFORMATION, WIRE SIZE, CONDUIT SIZE, TERMINATION LOCATION, AND DATA REQUIREMENTS ARE BASED UPON PRELIMINARY DESIGN LOAD INFORMATION AND HAS NOT BEEN CONFIRMED WITH VENDOR. VENDOR SUBMITTALS WERE NOT AVAILABLE PRIOR TO DRAWING ISSUE.
2. CONTRACTOR RESPONSIBLE FOR INSTALLATION OF DOOR CONTROLLERS AND TERMINATION OF ALL REQUIRED DOOR WIRING SCHEMATICS AND INSTALLATION DIAGRAMS IN 300 SERIES DRAWINGS.

KEYED NOTES:

- 1 EMERGENCY MEDICAL PUSH BUTTON. COORDINATE WITH OWNER.
- 2 ALL SMOKE DETECTORS AND STROBES SHALL BE CONNECTED TO EXISTING FACP ON THE FIRST FLOOR OF BUILDING 8.
- 3 ALL DEVICES IN ROOMS 124 AND 125 SHALL BE CGMP COMPATIBLE.
- 4 NOT USED.
- 5 VISUAL STROBE CONNECTED TO THE NEW TECH ELECTRONICS SYSTEM.
- 6 DOOR-RELEASE BUTTON.

0	02/18/11	S.L.	ISSUED PER PROJ MK725
NO.	DATE	ENGR.	DESCRIPTION
DRAWING REVISIONS			
JOB NO.	086778.00	PROJECT NO.	MK725
<div> COVIDIEN</div>			
BUILDING 5--ANNEX ELECTRICAL FIRST FLOOR POWER PLAN			
SITE	STL	PLANT 1	BLDG. 5 FLOOR 1
SCALE	1/4"=1'-0"	DATE	6/30/2008
DR. BY:	JLG	ENGR.	JJO
CHECKED			
DRAWING NO.	0005-920-008		REV. 0
THIS DRAWING IS THE PROPERTY OF COVIDIEN LTD. (OR ITS SUBSIDIARY) AND IS NOT TO BE REPRODUCED, COPIED OR USED FOR ANY PURPOSE EXCEPT AS SPECIFIED BY COVIDIEN LTD. © 2007 Mallinckrodt Inc. All rights reserved.			